

## Electricity In The District

District : Jalna

Report : Yearly  
Reporting Year : 2010-11

Total Use Of Electricity 000 KWH										
Taluka	Domestic	Commercial	Industrial	Public Lighting	Agriculture	Other	Total	Per Captia Consumption Of Electricity	Total Electricity Connections (Lakhs)	Reference Year
1	2	3	4	5	6	7	8	9	10	11
Bhokardan	7500	1660	1900	2610	13940	630	28240	49.54	0.57	2010-11
Jafferabad	4940	670	1400	1910	20930	670	30520	84.78	0.36	2010-11
Jalna	44040	10030	17000	7590	6280	1270	86210	83.69	1.03	2010-11
Badnapur	3620	550	800	340	4120	320	9750	37.50	0.26	2010-11
Ambad	10040	1180	2300	570	9750	520	24360	55.36	0.44	2010-11
Ghansawangi	4440	650	800	490	15480	170	22030	64.79	0.34	2010-11
Partur	9030	1430	1600	440	4170	300	16970	44.65	0.38	2010-11
Mantha	5370	850	700	420	1750	420	9510	29.72	0.32	2010-11
<b>Total</b>	<b>88980</b>	<b>17020</b>	<b>26500</b>	<b>14370</b>	<b>76420</b>	<b>4300</b>	<b>227590</b>	<b>56.25</b>	<b>3.70</b>	

Source :  
'Superintending Engineer, MAHADISCOM'

Navigation Path :  
www.mahasdb.maharashtra.gov.in > Home > Jalna > Energy > Reports

This report should be updated within 2 months after completion of Reporting period  
Data as on May 8, 2013 on SDB